

DATA REQUEST RESPONSE
Bear Valley Electric Service
BVES R.18-10-007

Response provided by: Paul Marconi
Title: Director, Bear Valley Electric Service
Data Request Number: Data Request No. CalPA-BV-R1810007-003
Data Request Originator: Shelby Chase
Date Received: March 11, 2019
Date Due: March 14, 2019
Date Provided: March 11, 2019

Data Request No. CalPA-BV-R1810007-002. Received via email from Shelby Case (CalPA) on March 11, 2019: included in Data request email is an excel spreadsheet titled “CalPA-BVES-R1810007-003”.

- 1. Please fill in all requested information related to BVES’ service territory in the attached Excel worksheet.**

Response:

Please see attached spreadsheet titled “BVES response to CalPA-BV-R1810007-003 Attachment A”.

Please note:

- BVES provided line miles not circuit miles (based on how the columns are labels).
- BVES does not own and operate any transmission infrastructure. Although it has sub-transmission lines (34.4 kV), it considers these lines as distribution assets, given the voltage.
- BVES’ entire service area is within the HFTD – mostly Tier 2 (95%) and Tier 3 (5%)